Emission Test Certificate

Tuesday May 6th, 2007

Supplier: TAG (PO Box 681, South Yarra, Victoria 3141)

Sample Description: Bolon woven vinyl

Date Tested: April 2008

Test Method: Carpet & Rug Institute Green Label test program incorporating ASTM D5116-97 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products".

Emission Data:

Carpet & Rug Institute Green Label Specification	Bolon
Total Volatile Organic Compound emission rate < 0.5 mg/m^2/hr (24 hours)	Total Volatile Organic Compound emission rate 0.35 mg/m^2/hr (24 hours)
Formaldehyde emission rate < 0.05 mg/m^2/hr (24 hours)	Formaldehyde emission rate < 0.01 mg/m^2/hr (24 hours)
4-Phenylcyclohexene emission rate < 0.05 mg/m^2/hr (24 hours)	4-Phenylcyclohexene emission rate < 0.01 mg/m^2/hr (24 hours)
Styrene emission rate < 0.4 mg/m^2/hr (24 hours)	Styrene emission rate < 0.01 mg/m^2/hr (24 hours)

Vyt Garnys

Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

CV080413